

Lighting Control System for Industrial Locations

User Guide





Dialight Gateway Quick Start Manual
READ AND FOLLOW ALL SAFETY INSTRUCTIONS



- ***DO NOT let any supply cords touch hot surfaces higher than cord ratings.***
- ***DO NOT mount near gas or electric heaters***
- ***Equipment should be mounted in locations and at heights where it will not be subjected to tampering by unauthorized personnel.***
- ***The use of accessory equipment not recommended by the manufacturer may cause unsafe conditions.***
- ***DO NOT use this equipment for other than intended use.***
- ***AC Generators must not be used to power the Gateway.***
- ***Sharing breakers with welders, grinders or other hand or high noise equipment will void all warranties.***
- ***In high surge or other bad power locations the use of additional suitable SPD's is highly recommended.***

SAVE THESE INSTRUCTIONS!!

- ***The operation and maintenance must be carried out by authorized personnel.***
- ***Repairs and Installation must only be carried out by a qualified electrician.***
- ***Only genuine Dialight replacement parts must be used when unforeseen repairs are required.***
- ***Observe the national safety rules and regulations during installation!***
- ***Earth Grounding is required throughout the install process. Failure to do so could void all warranties!***
- ***No alterations should be done without the agreement from Dialight Corp. Alterations other than written in this manual will void all warranties.***
- ***The use of UPS backup systems are allowed but must be approved by Dialight.***

SAVE THESE INSTRUCTIONS!!



Contents

Contents	3
Introduction	5
Gateway Visual Overview	6
Mounting & Placement.....	7
Additional Mounting Considerations.....	8
Installing Antenna(s)	8
Powering On the Gateway for the First Time	8
Installation Instruction of RJ45	9
Gateway Interface Features.....	10
Gateway Web Application	11
Stand-Alone Gateway User Interface Web Application Login	11
Login Screen.....	12
Home Page	12
Info Bar Detail	13
Menu Options.....	15
Home.....	15
About	15
Logout.....	15
Manage	15
Manage Alerts	15
Group Control	17
Net Analysis	18
Configure	21
Step-by-Step Commissioning Wizard	21
Discover your Devices	22
Check Network Health on Network Analysis Page	24
Create Groups on the Configure Groups Page.....	24
Create Schedules to Control Your New Groups	25
Add Schedules to Groups	27
Configure Active Alerts	27
System.....	28
Alerts.....	29
Configure Devices	29
Configure Device Page	30
Parameter Descriptions	30
Configure Gateways	31
Configure Groups.....	32
Parameters and Pages.....	33
Wireless Occupancy Sensor Configuration	33
Daylight Harvesting Configuration	34
Add Schedules to a Group.....	36
Schedules	37
Creating a New Schedule	37
Configuring a Schedule.....	38
Users	40

Gateway LED Panel Indicators	41
<i>Power LED</i>	41
<i>OFF / Resume</i>	41
<i>Alert</i>	41
<i>Emergency</i>	42
<i>Ethernet</i>	42
<i>Wireless Network</i>	42
Gateway Local Controls	43
<i>OFF/RESUME, Emergency Buttons</i>	43
Appendix A – Advanced Settings	44
<i>Settings</i>	45
<i>Model Information</i>	45
<i>Wired Ethernet</i>	45
<i>Wi-Fi</i>	45
<i>Enterprise Server</i>	46
<i>Resets</i>	46
<i>Debug Assistance</i>	46
<i>Gateway Control</i>	46

Introduction

This manual is for orientation and a quick guide to the installation process and configuration of the Control and Monitoring gateway.

Included in this manual:

System overview


System configuration instructions

User Interface overview

Note:



In order to use Wi-Fi functionality, a Wi-Fi enabled device must be used.

Gateway Visual Overview



In the box

- 1x –Gateway
- 1x – Sealed RJ45 network connector assembly
- 1x – Antenna
- 1x – Antenna (Wi-Fi Gateway only)



Additional Mounting Considerations

- For optimal performance gateway should have direct line of sight (LoS) to at least one light fixture to be controlled.
- Do not mount gateway behind walls or behind/in metal cages. This will diminish the wireless signal.
- Ensure that the mounting bolts are securely fastened to a solid backing.


Installing Antenna(s)

- To ensure maximum performance, install antenna(s) to 3-5 in-lb (0.3-0.6 N-m).

Powering On the Gateway for the First Time

The Gateway does not have an external power switch; it will automatically turn on when power is connected.

- Be certain electrical power is OFF before and during installation and maintenance.
- Device must be connected to a wiring system with an equipment grounding conductor.
- Make sure the supply voltage is the same as the device rated voltage.
- The terminal block is fitted with a user replaceable 2A Time Delay fuse on the input labeled 'line' only.
- To maintain seal integrity, a suitably rated cord grip must be used in accordance with manufacturer recommendations.
- Apply AC power to terminal block.
 - Line voltage connects to the large grey terminal. Neutral connects to the smaller grey terminal. Earth/Safety Ground connects to the green terminal.




- AC supply requirements, 110-277VAC, 50/60Hz, capable of supplying 1 Amp.
- A minimum of 14 AWG(2.08mm²) cable is to be used. The terminal block can accept up to 8 AWG(10.55mm²) cable.

- Once power has been applied wait for the gateway to start up. (approximately 1 minute)
- Once power LED turns ON you can control your gateway via Wi-Fi or Ethernet connection.


Installation Instruction of RJ45

1. Apply sealant
2. Slide cable thru fitting
3. Mate plug and jack inside Ethernet port
4. Fully seat supplied feed thru to Ethernet port
5. Tighten cinch nut only if sealant is in proper location



Gateway Interface Features

Gateway LED Interface gives you current status of controls enabled LED fixture system performance.



Note: Once activated, both buttons will override the regular operation of the lighting system

Gateway Web Application


Stand-Alone Gateway User Interface Web Application Login

Supported Browsers

- Dialight supports browser interaction with the control system using the following browsers:
 - Google Chrome v. 42 or newer
 - Mozilla Firefox v. 40 or newer
- Using Internet Explorer may lead to performance/visual issues

Launching the UI though LAN wired connection

- When using a wired LAN, you must set up the IP address of your Laptop/Desktop to 192.168.1.20 and its subnet mask to 255.255.255.0 using Windows LAN configuration utility as shown in Figure below.



- Once configured, open the Google Chrome Browser and type into its address bar: 192.168.1.150 and then hit ENTER.


NOTE: Wi-Fi connection is only possible for model number GUAW24AG

Launching the UI though Wi-Fi connection

- If you choose to use WIFI to access the Gateway, then make sure to enable the Wi-Fi interface on your Laptop/Desktop. Join the Dialight_GW_XXXX network with the password DialightGW. Each Gateway will have a unique set of numbers/letters for the XXXX portion of the Wi-Fi network name.

- Open one of the supported browsers on your Laptop/Desktop machine and using the address bar browse to address 10.10.0.1.

Login Screen



DACS
for
Standalone
Gateways


Username

Password

Login

- Enter default *Username*: **admin**
- Enter default *Password*: **password**
- Click Login

Home Page



a. Date & Time

b. Alerts

c. Off

d. Gateway Override (G.O.)

e. Emergency

f. Menu

16 October 2017
15 : 13 : 57

63

DACS SC

Active Alerts : 63

Devices Online : 25/65



DLH commanded Group 1 to 5%

Emergency Override

Anthony Demotta - in BLUE BLAY
SABLE SNAPE
https://www.scribd.com/...
antonio.demotta@dialed.com

Info Bar Detail

a. Date & Time

- DACS Server Date 
 - Date displayed by Day, Month, Year
- DACS Server Time (24 Hour time) 
 - Time displayed by Hour, Minute, Second
- Auto-Logout (60 Minute countdown)
 - Hover cursor over time, tooltip displays countdown time.
 - The system automatically logs the user out after 60 minutes of inactivity.

b. Unacknowledged Alerts indicator:




- Displays number of unacknowledged alerts
- Click on Alert icon- Manage Alerts page opens

c. Off



- Turns off lights for entire system!
- All lighting devices go to 0% brightness
- Off Icon will turn yellow while in off mode
- Click on icon to turn off lights and to resume previous lighting state
- All lighting devices return to their previous state after deactivating button.

d. Gateway Override (G.O)



- Displays the status of the Emergency Override button on the gateway
- The Gateway Override (G.O.) will turn yellow and blink when the Emergency Override button is pressed on the gateway

e. Emergency Override



- Turns Emergency Override on for entire system!
- All lighting devices go to 100% brightness
- Emergency Override Icon will flash while in override mode
- Click on icon to enable or disable emergency override
- All lighting devices return to their previous state when override is turned off

Note: Emergency Override will override all functions of the gateway while active (scheduling, manual control, off/resume, etc.). To resume these functions, the button must be turned off.

f. Menu Icon



Note - The Menu Icon is the main method to access all of the pages in the UI.



Menu Options

This section of the manual will review the features found on each page of the user interface.

Home

- Selecting Home icon returns user to homepage

About

- Selecting About icon displays an information page:



Logout

- Selecting Logout locks GUI
- User must log back into system

Manage


The manage section contains links to pages having to do with managing various portions of the system including groups, alerts, devices etc.

Manage Alerts

- Select Alerts icon to open Manage Alerts page
- Date and time event occurred
- Alert description
- Name of device
- Connection status

- Severity level of the alert

Selecting acknowledge or un-acknowledge alert



- Acknowledging alerts, clears alert from total number of alerts displayed in the top menu.
- Acknowledged alerts will remain on alerts page.
- Selecting Clear Ack



- Clears all acknowledged alerts

Note: This action cannot be undone



Group Override Icon




- Selecting Group icon allows user to manually control light level of lighting devices in that group.
- Selecting Group icon a second time disables group control.

Note: Groups must be created from Manage Groups screen.

Note: Clicking on this icon enables and disabled Group Manual Control.

- User defined groups
 - Groups are built to meet user demands.
- All Devices

All devices is a special group that automatically has all devices associated with it. All lights in the system may be controlled by manually controlling the group named “All Devices”.




- Select ALL Devices Group icon



- User now can control all devices manually using slide bar.
- Select All Devices icon a second time to disable group control.

Note: this slider will override all lights, regardless of what group they belong to.

This screen is ideal for overriding scheduled dim values on single groups as well as the entire lighting system.




Net Analysis



The Net Analysis page shows a graphical representation of the tree formed by the wireless mesh network that is used to control the lights. This is useful in understanding the network connectivity and general health of the wireless network. This is helpful for troubleshooting issues on site.

The figure below shows the Gateway on the left, shown as a square, and devices on the right, shown as circles. The device names or UID are displayed next to their icon. Clicking on Device names allows easy identification and naming.



Hovering the mouse pointer over the Gateway name displays:


- Name: Standalone Gateway
- Device_Type: gateway
- Model_Name: High Bay Gateway
- UID: GW:xx:xx:xx:xx:xx:xx Where the xx values represent a unique set id number for each gateway.

Clicking on device name:

- Device Modal Popup
- Device Type and Model Name (auto-populated)
- User can Name device
- User can Identify device



- **Configure Button**
 - Select the configure icon to set the refresh rate of the display.



Configure

The Configure category of GUI pages is concerned with providing tools that help to set up and commission the lighting system.


Step-by-Step Commissioning Wizard



A Wizard has been provided to help walk you through the common steps involved in commissioning the lighting system. From the commission menu option you will be taken through a series of steps that will get the lighting system up and running.

- Select Commission icon

Note: All nodes (lights and sensors) should be installed and powered on at this point)



- To start commissioning *Select Next*





Discover your Devices

The Commissioning Wizard will first take you to the Device Discovery Page to enable the system to discover devices.

- Select discover icon
- Discover icon flashes while in discover mode
- Select Discover icon a second time to disable discover mode
- Discover will time-out by itself after being on for 15 minutes



If you need for some reason to clear the system you may delete all devices.

- Delete All Button



- *Delete All* icon
- User will Delete all devices once Delete is confirmed



- Identify Icon



- Select Identify icon
- Allows lighting devices to be identified
- Lighting device will flash on and off
- Select identify icon a second time to turn identify off

Note: use this functionality to determine the location of each fixture within your facility. Name them based on location for easy grouping/control

Configure Icon

- Select Configure icon
- Device name can be changed
- Manual Dim Level can be set 0% to 100%
- Device can be identified
- All other fields are auto generated



Current system power consumption : 0 Watts

Dialight Architecture for Control Systems

- Select Back icon to return to devices page.



- Select Next Icon to go to Network Analysis page.



Check Network Health on Network Analysis Page

The Commissioning Wizard then takes you to the Network Analysis Page so you can review the network topology. Clicking on the UID tags will allow you an efficient method for identifying and naming devices.



- Select Next Icon to go to the Configure Groups page.



Create Groups on the Configure Groups Page


The Commissioning Wizard next takes you to the Configure Groups Page to help create groups for lighting control commands.



Click to add a new group.




Dialog box titled "Add new group" with fields for "Group Name" and "Description". At the bottom are "Cancel" and "Save" buttons.

- Assign devices to groups
- Click on device names to select them and add them to the group. Selected devices are highlighted in green.




- Select Save when you're finished. 
- Select Next 

Create Schedules to Control Your New Groups

- Select Add schedules icon 
- Create schedule name
- Create schedule description
- Select save or cancel



The dialog box titled "Add new schedule" contains two input fields: "Schedule Name" and "Description". At the bottom, there are two buttons: "Cancel" with a close icon and "Save" with a checkmark icon.

- Click on Configure icon 

The configure icon provides a collection of features used to set up and configure your new schedule.


- Select days for schedule to run
 - Click on day of week to select

Schedules consist of a collection of events which define the time at which the event action is executed. Once you have created and named your new schedule the next step is to add events to the schedule.

1. Click on add event button to add a schedule event 



- Select event time – this is the time that the event will be executed.
- Select type of event – this determines what kind of event it is and what action it will perform.
 - Light level
 - Occupancy Sensor
 - Daylight Harvesting
- Select Value – this is a value associated with the event, such as the level of a dimmer event. Some typical event values are:
 - On
 - Off
 - 10% to 100%
- Click delete icon to remove event. 

Levels Graph


The Levels Graph section of the Manage Schedules Page shows a graphical representation of the schedule that you are working on.

- Click on Level, DLH, OCC beneath levels graph
- Graph will populate with scheduled events
- Hovering over the levels graph will also display event settings



Add Schedules to Groups

The next page of the Commissioning Wizard provides tools to allow you to add one or more schedules to the group that was created in the previous step.

- Select Add schedules to this group icon.  Schedules
- Click on the schedules you would like to include such that the selected schedules are checked and turn green.



- Click on Save to save your schedule configuration.

Click Next



Configure Active Alerts

The next page offers an easy way to enable alerts for the system. Click to turn on alert reporting for the associated type.

- Click on alert to select
 - Device Dropped
 - Device temperature
 - Gateway temperature
 - Low Battery

This concludes the Commissioning Wizard.

Note: once your system is commissioned, you are free to make changes to the system without having to re-commission. This can be done easily by using the menu options under the '**Configure**' section

System

The Configure System page provides an interface that is used to configure system parameters. Currently this includes configuring the time and date settings.



The screenshot shows the 'System' configuration page. At the top, there is a status bar with a menu icon, the date '2 November 2017', the time '13 : 39 : 39', and an 'Emergency Override' button. Below the status bar, there are 'Cancel' and 'Save' buttons. The main content area is titled 'Date/Time' and contains the following fields:

- NTP Active: ☐
- Date: 2 / November / 2017
- Time: 13 : 39

- Setting the system time
 - Enter date
 - Enter time (24 Hour Time)
 - Select Save
 - You will be automatically logged out of the server
 - Log back into light controller and verify date and time are correct



The screenshot shows the 'System' configuration page. At the top, there is a status bar with a menu icon, the date '2 November 2017', the time '13 : 42 : 02', and an 'Emergency Override' button. Below the status bar, there are 'Cancel' and 'Save' buttons. The main content area is titled 'Date/Time' and contains the following fields:

- NTP Active: ☒
- Timezone: America / Denver
- NTP Server: 127.0.0.1

- Enable NTP Network Time
 - Enable NTP (Network Time Protocol) checkbox
 - Set time zone (Area and City)
 - Set NTP server (i.e. pool.ntp.org)
 - Note that NTP requires a valid NTP server accessible on the network to work.

Note - When NTP is not enabled, the system defaults to the UTC time zone. If you would like to specify your local time zone to enable automatic time changes for daylight savings time, you

need to set the date and time to the correct time for UTC. Then enable NTP and set your local time zone and the server address to 127.0.0.1 (local loopback address). This will allow the system to follow the daylight savings time changes for your local time zone, but NTP will not make any automatic changes to the clock.


Alerts


The alerting mechanism available in Stand Alone mode is relatively straight forward and offers options for enabling 2 kinds of alerts:



- Device Dropped
- Low Battery

Configure Devices

The Configure Devices page shows a list containing all of the devices that are currently discovered on the system.




- The “Devices (68/68)” icon at the top of the screen indicates that 68 devices of 68 discovered are currently online and responding.
- The “Discover” button turns on device discovery, as described in the Commissioning portion of this manual. 

- The “Delete All” button will delete all devices from the system, after a confirmation dialog is acknowledged. 
- Device configuration is available on the Device Info page which is available by clicking on the gear icon associated with each device. 

Configure Device Page

The Configure Device page displays all available information for the associated device. This information will vary depending on what kind of device is being viewed.




Parameter Descriptions

- Name – The user specified name of this device.
- Device Type – The type of device being displayed.
- Model – The model number of the device being displayed.
- Dim Level – A local control that allows the light to be temporarily set to a manual level for the purpose of testing. The level will return to the proper scheduled level for the device in its group once the Configure Device page is exited.
- Identify – Turning Identify on will cause the light to flash at ~ 1 flash per second. This is useful in identifying which fixture, out of a large installation of fixtures, is being currently displayed.
- Is Connected – This shows if the light is currently active on the control network.
- Lamp Hours – The total number of hours the fixture has been on and outputting light.
- Num Groups – This is the maximum number of groups that the device may be a part of. Some devices have limitations and may only be able to be added to a particular number of groups.

- RF Parent – This field displays the UID of the device that is this device’s parent in the network tree. See the Net Analysis page in this manual for additional information on the structure of the wireless network.
- RF Strength – This is a measure of the received signal strength for this device in the network.
- Software Version – This is the currently installed firmware revision running on the device.
- UID – This is a unique identifier string for the device. Each device in the lighting system has a unique UID which is used to positively identify it.

Configure Gateways

The Configure Gateways page provides a mechanism for adjusting various settings for the gateway controller.



The screenshot shows the 'Configure Gateway' web interface. It has a dark blue header with 'Configure Gateway' and a 'Save' button. The main content area is divided into two sections: 'Model Information' and 'Settings'. The 'Model Information' section includes fields for Model Name (High Bay Gateway), Model ID (H1001001000), Firmware Ver (1.0.0), and Software Ver (1.0). The 'Settings' section includes fields for Name (Gateway 01), Description (Gen 1.5 Gateway), Network Pan ID (12), Channel (12), Broadcast (checked), Type (D-DMZ), Address (10.4.0.1), Broadcast (255.255.255.0), Gateway (10.4.0.1), Wireless (checked), Address (10.10.0.1), Channel (1), Access Point Name (Dialight), and Password (Dialight). A 'Status' button is next to the Type field.

- Model Information
 - Model Name – Manufacturer model name of the gateway.
 - Model ID – part number of the gateway.
 - Firmware Version – Internal firmware version info.
 - Software Version – Internal Software version info.
- Settings
 - Name – User settable text name for identifying the gateway.
 - Description - Textual description of the gateway. Could include notes or location description.
 - Network Pan ID – Numeric id for wireless network.

- Channel – User selectable channel for the wireless lighting network.
- Ethernet
 - Type – Select DHCP or Static for IP address configuration type.
 - Address – Manually entered IP address.
 - Netmask – Manually entered netmask.
 - Gateway – Manually entered Ethernet network gateway address.
- Wireless
 - Enabled – This allows Wi-Fi to be turned on and off.
 - Address – This specifies the Wi-Fi IP address to connect to.
 - Channel – User selectable Wi-Fi channel.
 - SSID – User settable SSID for the Wi-Fi network.
 - Password – Wi-Fi password.

Configure Groups

The Configure Groups page provides tools that are used to create and set up groups of devices which will be operated on schedules of control events. The Configure Groups page initially shows a list of all existing groups in the system.




Clicking on the Configure Group icon




for a particular group will open the


Configure Group page.




This page contains a collection of parameters and settings, as well as links to pages for managing which devices are members of the group, a page for associating one of more schedules with the group and 2 pages for configuring sensors to work with the group. Finally, the lower portion of the page shows a week-long graph which illustrates the activity of the lighting system over a week's time.

Parameters and Pages

- Name – User defined group name.
- Description – User created text description for the group.
- Devices icon  - This opens a page used to add / remove devices form the group. The user selects each device that is intended to be in the group. Clicking on a device button selects / deselects that device.



- WOS Stepdown Icon  - Click on the icon to open a dialog box used for configuring daylight harvesting.


Wireless Occupancy Sensor Configuration


When enabled in a schedule and motion is detected the configured group will be commanded to follow the configured stepdown schedule.

- Set dim value for all three stepdown steps



- Set a duration for each of 3 stepdown steps.



- Daylight Harvesting (DLH) DLH Configure Icon  - Click on this icon to open a page used to configure daylight harvesting.


Daylight Harvesting Configuration

Daylight Harvesting allows sunlight to supplement electric lighting to affect energy savings. DLH uses installed ambient light sensors (WDLH sensors) to measure the light level in a work-space, and then allows energy savings by dimming electric lighting to maintain a constant illumination.

Daylight harvesting must be calibrated by setting a target illuminance for the system. This is the light level that the DLH algorithm we seek to maintain.

- Click on the DLH icon to open the configuration window.

- Set target light level on dim slider
- Select the operating mode (Average, Maximum, and Minimum). This is useful if more than one sensor has been installed and assigned to the group.
 - Average will use the illuminance level that is the average of the levels read from the sensors.
 - Maximum will use the highest reading from the collection of sensors.
 - Minimum will use the lowest reading from the collection of sensors.
- Adjust the Level slider to achieve desired illuminance. This must be done when the area is not being illuminated by supplemental light, such as sunlight. Note that the “Measured Illuminance field will automatically update to show the measured light level.
- Select “Save” when complete. This step sets the target illuminance for the DLH algorithm.



DLH Target


Level 75

Mode

Measured Illuminance (lx)

- Select Schedules Icon  to add or remove schedules from this group.

- Click on the labeled buttons to select desired schedules and click “Save” and then “Back”.




Schedules

Schedules are collections of control events used to operate on groups of devices in the lighting system. Schedules are created, named and saved, to be later applied to one or more groups.

Example: Consider the case in which you have a large number of isles in a warehouse which at times need to be controlled as separate groups but essentially follow the same schedule. By defining and naming schedules as separate entities it is possible to create a single schedule and apply it multiple times. Therefore commissioning the warehouse does not require entering in the schedule for each isle.

Creating a New Schedule

- Choose the “Schedules” option from the menu to go to the Schedules page.




- Click on the “Add +” button to create a new schedule.
 - Enter a name and description for the group and click “Save”.
 - Back on the Schedules page, your new schedule will be listed. Click on the gear icon to configure the group.

Configuring a Schedule


Schedules define 24 hours of lighting system events, and that 24 hours may be applied to any of the 7 days of the week creating a week-long schedule. To configure a schedule you must perform the following steps:

- Select which days of the week the schedule is to be active.
- Add light level events to specify what light level a group running the schedule should be maintained at any specific time.
- Add events to enable / disable Daylight Harvesting and Occupancy Sensing, if desired.



Instructions to configure schedule:

1. Select which days of the week the schedule is to run by clicking on the days of the week.
2. Add Light Level dimming events to the schedule by clicking on the “Add +” button.



3. Enter the Time, Type (Light Level) and Value. Click “Ok.”
4. Repeat the previous 2 steps and add all of the desired dimmer commands.
5. Add events for enabling / disabling daylight harvesting and occupancy sensing in the same manner, but the event Type and Value will correspond to the desired sensor actions. **Note** – The schedule only enables and disables sensor activity with schedule events. The behavior of the sensors and configuration of daylight harvesting or occupancy sensing is done in Group Configuration for that group.

Users


The standalone version of Dialight's lighting control software supports only a single user login.

Username: admin

Password: password (by default)

The User page allows the default password to be changed.

Important: You should change the password immediately after logging in for the first time.



Gateway LED Panel Indicators



The gateway's front panel provides several helpful LED indicators that are useful in troubleshooting common issues.

Power LED

When Gateway is turned on this LED will always be steady green

OFF / Resume

This indicator will light when the system has been commanded to the OFF state via the front panel button. When off the system is running normally.

Alert

The Alert LED shows various top level alerts in the system such as a light losing network connection.

Event	LED behavior	Priority
Light node disconnected	Steady ON	1
Other nodes disconnected	Blink 0.2 sec ON – 0.2 sec OFF	2
OCCS Low voltage	Blink 0.25 sec ON – 1 sec OFF	3

Alert LED is OFF otherwise

Emergency

If the Emergency (override) button is pushed then this LED will be steady ON

Ethernet

The Ethernet LED uses blink codes to convey 6 different states, as shown in the table below. Information about the gateway network settings and its connected status is represented.

Static IP	DHCP	Factory default IP (192.168.1.150)	Ethernet connectivity	LED State
Yes	NO	Yes	NO	OFF
Yes	NO	Yes	Yes	Blink 0.2 sec ON – 0.2 sec OFF
Yes	No	No	No	Blink 0.25 sec ON – 1 sec OFF
Yes	No	No	Yes	LED Steady On
No	Yes	No	No	Blink 1 sec ON – 0.25 sec OFF
No	Yes	No	Yes	LED Steady On

Wireless Network

This LED displays basic information about the wireless mesh lighting network such as if discovery is currently running and if there are or are not any devices currently in the device list.

Discovery	Devices in the list	LED status
ON	N/A	Blink 0.2 sec ON – 0.2 sec OFF
OFF	No devices	LED OFF
OFF	We have devices	Steady ON

Gateway Local Controls

OFF/RESUME, Emergency Buttons

The Emergency E-Stop button provides a failsafe way to turn all of the lights on in the system, regardless of configuration, setting or schedule. When the Emergency Button is pressed, all lights in the network will be commanded on. They shall remain on until the button is released (twist), at which time they will resume to their currently scheduled levels.

The OFF / Resume button provides a convenient way to turn all of the lights in the system off. Pressing and holding this button for 3 seconds will cause all lights in the system to be commanded off. Pressing the button a second time will cause all of the lights to resume their regularly scheduled dimmer levels.

The following table illustrates the interaction between the buttons, the panel LED indicators and the system run state.

OFF/Resume Button State	E-Override Button State	Lighting System State	OFF/RES LED	E-OR LED
States: OFF, RESUME	States: OVERRIDE, RESUME			
RESUME	RESUME	RUN Schedule	OFF	OFF
RESUME	OVERRIDE	Override: Lights 100%	OFF	ON
OFF	RESUME	Lights Off	ON	OFF
OFF	OVERRIDE	Override: Lights 100%	OFF	ON
The E-Override button is a maintained push-pull (twist release) button				
The OFF/Resume button is a momentary type. Holding the button for 5 seconds toggles its state. The initial state is Resume.				


Appendix A – Advanced Settings

You may access the Advanced Settings page of the gateway by browsing to port 56005 at the gateway's IP address. For example:

<http://10.4.80.53:56005>

Where the example gateway is located at IP address 10.4.80.53.

WARNING: Changing these settings can affect networking and wireless for this gateway. Please read very carefully before saving any changes. Refer to the numbered sections for a description of each setting



The screenshot shows the 'Administrative Settings' page of a Dialight gateway. The page is divided into several sections, each with a title bar and an 'Update' button. The sections and their settings are as follows:

- Settings (1):** Name: Gateway 04, Description: Gen 2 Gateway.
- Model Information (2):** Model Name: High Bay Gateway, Model Id: HLCMC-04N-S2V0, Firmware Ver: 0.1, Software Ver: A1.
- Wired Ethernet (3):** Type: DHCP (selected), Address: 10.4.80.64, Netmask: 255.255.255.0, Gateway: 10.4.80.1.
- WiFi (4):** Enable WiFi: (checked), Address: 10.10.0.1, SSID: Dialight_04N_04, Password: Dialight04N, WiFi Channel: 1, 2.412 GHz.
- Enterprise Server (5):** DACS Mode: Standalone (selected), Address: 10.4.80.9, Port: 80.
- Resets (6):** Password Reset, Node Release, Factory Reset.
- Debug Assistance (7):** Create Log Backup.
- Gateway Control (8):** Change Control Panel Y Axis Orientation, Reboot Gateway, Shutdown Gateway.

Settings

Section 1

This section is informational. There are two fields which provide information on the gateway.

The first is the Gateway Name. This field can be changed in the regular Gateway GUI by going to Menu -> Configure -> Gateway. Once changed from the GUI, the Gateway name will update on the Administrative Settings page. This field can be useful for identifying gateway location within a facility (EX: Storage Room 1)

The second field is Description. This field allows the user to add a custom description pertaining to the Gateway. This field can be useful for describing location or other useful gateway information. This field can be changed in the regular Gateway GUI by going to Menu -> Configure -> Gateway

Model Information

Section 2

This section is informational. In this section, you can find hardware and firmware information pertaining to the gateway. This information Includes Model Name, Model ID, Firmware Version, and Software Version. This information will be automatically updated when firmware changes are made to the gateway

Wired Ethernet

Section 3

This section allows the user to modify the network settings for the wired Ethernet port located on the bottom of the gateway. Once connected to an external network, the gateway will follow all network settings defined in this section. The network type can be changed from static IP to DHCP based on user requirements.

NOTE: record all network information before selecting 'Update'. The gateway will reboot or reset and you will need this new network information to access the system

Wi-Fi

Section 4

This section allows the user to modify the network settings for the Local Wireless feature of the Gateway. Once enabled, the user can change various settings such as SSID and Password based on security requirements.

NOTE: record all network information before selecting 'Update'. The gateway will reboot or reset and you will need this new network information to access the system

Enterprise Server

Section 5

This section is useful for changing the gateway to Enterprise Mode, which enables a connection to a DACS system. Once set to enterprise mode, this gateway will not function without a DACS server present. After switching the gateway using the Enterprise radio button, enter the IP address of your DACS system. Ensure all information is correct before selecting 'Update' as the gateway will reboot in Enterprise mode.

NOTE: If you are using the Gateway as part of a standalone system, the Gateway **MUST** be in Standalone Mode to operate

Resets

Section 6

This section allows the user to reset forgotten passwords, nodes, and even the gateway itself. Selecting the *Password Reset* option will reset the login password to factory default. *Node Release* is useful when you have lights which were previously connected to a non-working gateway. Before they are connected to a new gateway, they need to be released. This button will prompt the user before performing a node release. Finally, The *Factory Reset* button will return the Gateway to factory default settings

Debug Assistance

Section 7

This section allows the user to create and download a debug file. This file is useful when debugging problems with the gateway.

Gateway Control

Section 8

This section allows the user to reboot and shut down the Gateway. While there should never be a reason to reboot the gateway, it is important that the gateway is shut down before power is removed.

Important – To avoid data loss it is important that the Gateway is shut down using the Shut Down mechanism located on this page **BEFORE** power is removed from the gateway. Failure to do so could result in system settings becoming corrupted.