

This information is provided only as an aid to understand the catalog numbers.

It is not to be used to build catalog numbers for circuit breakers or trip units as all combinations may not be available.

Table 2. Circuit breaker catalog number convention

PDG2 3 M 0225 P 2 M J																																																															
Breaker family PDG2 = Frame 2 Global UL / CSA / IEC / GB PDF2 = Frame 2 Global-100% UL / CSA / IEC / GB (uses PDG trip units) PDD2 = Frame 2 IEC / GB PDC2 = Frame 2 IEC / GB PDC9 = Frame 9 IEC / GB		Interrupting rating designator <table><tr><th>kA at 480 V (UL)</th><th>IA at 415 V (IEC)</th></tr><tr><td>F = 25</td><td>25</td></tr><tr><td>G = 35</td><td>35</td></tr><tr><td>K = 50</td><td>50</td></tr><tr><td>M = 65</td><td>70</td></tr><tr><td>N = 85</td><td>70</td></tr><tr><td>P = 100</td><td>100</td></tr></table>		kA at 480 V (UL)	IA at 415 V (IEC)	F = 25	25	G = 35	35	K = 50	50	M = 65	70	N = 85	70	P = 100	100	Continuous current rating <table><tr><td>0015 = 15 A</td></tr><tr><td>0020 = 20 A</td></tr><tr><td>0025 = 25 A</td></tr><tr><td>0030 = 30 A</td></tr><tr><td>0035 = 35 A</td></tr><tr><td>0040 = 40 A</td></tr><tr><td>0045 = 45 A</td></tr><tr><td>0050 = 50 A</td></tr><tr><td>0060 = 60 A</td></tr><tr><td>0063 = 63 A IEC only</td></tr><tr><td>0070 = 70 A</td></tr><tr><td>0080 = 80 A</td></tr><tr><td>0090 = 90 A</td></tr><tr><td>0100 = 100 A</td></tr><tr><td>0110 = 110 A</td></tr><tr><td>0125 = 125 A</td></tr><tr><td>0150 = 150 A</td></tr><tr><td>0160 = 160 A IEC only</td></tr><tr><td>0175 = 175 A</td></tr><tr><td>0200 = 200 A</td></tr><tr><td>0225 = 225 A</td></tr><tr><td>0250 = 250 A IEC only</td></tr></table>				0015 = 15 A	0020 = 20 A	0025 = 25 A	0030 = 30 A	0035 = 35 A	0040 = 40 A	0045 = 45 A	0050 = 50 A	0060 = 60 A	0063 = 63 A IEC only	0070 = 70 A	0080 = 80 A	0090 = 90 A	0100 = 100 A	0110 = 110 A	0125 = 125 A	0150 = 150 A	0160 = 160 A IEC only	0175 = 175 A	0200 = 200 A	0225 = 225 A	0250 = 250 A IEC only	Features <table><tr><td>N = None</td></tr><tr><td>R = Relays</td></tr><tr><td>Z = ZSI</td></tr><tr><td>M = Modbus</td></tr><tr><td>C = CAM interface</td></tr><tr><td>D = Modbus & CAM interface</td></tr><tr><td>W = ZSI & Modbus</td></tr><tr><td>X = ZSI & CAM interface</td></tr><tr><td>Y = ZSI, Modbus, & CAM interface</td></tr><tr><td>Magnetic Protection</td></tr><tr><td>A = Adjustable magnetic</td></tr><tr><td>F = Fixed magnetic</td></tr></table>		N = None	R = Relays	Z = ZSI	M = Modbus	C = CAM interface	D = Modbus & CAM interface	W = ZSI & Modbus	X = ZSI & CAM interface	Y = ZSI, Modbus, & CAM interface	Magnetic Protection	A = Adjustable magnetic	F = Fixed magnetic	Terminals included <table><tr><td>N = No terminals</td></tr><tr><td>J = Line and load terminals</td></tr><tr><td>K = Line only terminals</td></tr><tr><td>L = Load only terminals</td></tr></table>		N = No terminals	J = Line and load terminals	K = Line only terminals	L = Load only terminals
kA at 480 V (UL)	IA at 415 V (IEC)																																																														
F = 25	25																																																														
G = 35	35																																																														
K = 50	50																																																														
M = 65	70																																																														
N = 85	70																																																														
P = 100	100																																																														
0015 = 15 A																																																															
0020 = 20 A																																																															
0025 = 25 A																																																															
0030 = 30 A																																																															
0035 = 35 A																																																															
0040 = 40 A																																																															
0045 = 45 A																																																															
0050 = 50 A																																																															
0060 = 60 A																																																															
0063 = 63 A IEC only																																																															
0070 = 70 A																																																															
0080 = 80 A																																																															
0090 = 90 A																																																															
0100 = 100 A																																																															
0110 = 110 A																																																															
0125 = 125 A																																																															
0150 = 150 A																																																															
0160 = 160 A IEC only																																																															
0175 = 175 A																																																															
0200 = 200 A																																																															
0225 = 225 A																																																															
0250 = 250 A IEC only																																																															
N = None																																																															
R = Relays																																																															
Z = ZSI																																																															
M = Modbus																																																															
C = CAM interface																																																															
D = Modbus & CAM interface																																																															
W = ZSI & Modbus																																																															
X = ZSI & CAM interface																																																															
Y = ZSI, Modbus, & CAM interface																																																															
Magnetic Protection																																																															
A = Adjustable magnetic																																																															
F = Fixed magnetic																																																															
N = No terminals																																																															
J = Line and load terminals																																																															
K = Line only terminals																																																															
L = Load only terminals																																																															
Poles <table><tr><td>1 = 1 pole</td></tr><tr><td>2 = 2 pole</td></tr><tr><td>3 = 3 pole</td></tr><tr><td>4 = 4 pole with 100% neutral protection</td></tr><tr><td>6 = 4 pole with 60% neutral protection</td></tr><tr><td>0 = 4 pole with 0% neutral protection</td></tr></table>		1 = 1 pole	2 = 2 pole	3 = 3 pole	4 = 4 pole with 100% neutral protection	6 = 4 pole with 60% neutral protection	0 = 4 pole with 0% neutral protection	ETU trip unit style <table><tr><td>B = PXR 10</td></tr><tr><td>E = PXR 20</td></tr><tr><td>D = PXR 200</td></tr><tr><td>P = PXR 25</td></tr><tr><td>Thermal magnetic style</td></tr><tr><td>T = Thermal</td></tr><tr><td>V = Thermal 50° C calibrated</td></tr></table>		B = PXR 10	E = PXR 20	D = PXR 200	P = PXR 25	Thermal magnetic style	T = Thermal	V = Thermal 50° C calibrated	ETU protection style <table><tr><td>1 = LI</td></tr><tr><td>2 = LSI</td></tr><tr><td>3 = LSIG</td></tr><tr><td>4 = LSI ARMS</td></tr><tr><td>5 = LSIG ARMS</td></tr><tr><td>Thermal magnetic style</td></tr><tr><td>F = Thermal</td></tr><tr><td>A= Thermal 50° C calibrated</td></tr></table>		1 = LI	2 = LSI	3 = LSIG	4 = LSI ARMS	5 = LSIG ARMS	Thermal magnetic style	F = Thermal	A= Thermal 50° C calibrated																																					
1 = 1 pole																																																															
2 = 2 pole																																																															
3 = 3 pole																																																															
4 = 4 pole with 100% neutral protection																																																															
6 = 4 pole with 60% neutral protection																																																															
0 = 4 pole with 0% neutral protection																																																															
B = PXR 10																																																															
E = PXR 20																																																															
D = PXR 200																																																															
P = PXR 25																																																															
Thermal magnetic style																																																															
T = Thermal																																																															
V = Thermal 50° C calibrated																																																															
1 = LI																																																															
2 = LSI																																																															
3 = LSIG																																																															
4 = LSI ARMS																																																															
5 = LSIG ARMS																																																															
Thermal magnetic style																																																															
F = Thermal																																																															
A= Thermal 50° C calibrated																																																															

Note: IEC standard breakers include the CE mark; GB standard breakers include the CCC mark.