



Meter Sockets



RH173CR



RH173GR



RL178GRJ

100 Continuous Amp Ring Type Meter Mounting Equipment No Bypass, 3 Phase, 4 Wire, 600V Commercial/Industrial

Catalog Number	Dimensions (inches)			Cont. Amps	Service	Wire Range	No. of Jaws	Hub Opening	KO Fig.	List Price \$	Notes
	H	W	D								
7 TERMINAL											
SE750CR	16.1	8.0	4.4	100	OH	#14-1/0	7	RX Opening	36	166.00	⑤

200 Continuous Amp Ringless Type Meter Mounting Equipment Lever Bypass, 1 Phase, 3 Wire or 3 Phase, 3 Wire, 600V Commercial/Industrial

(These units not rated for 3 Phase, 4 Wire Service)

Catalog Number	Dimensions (inches)			Cont. Amps	Service	Wire Range	No. of Jaws	Hub Opening	KO Fig.	List Price \$	Notes
	H	W	D								
5 TERMINAL											
RH173CR	19.0	13.0	5.1	200	OH/UG	#6-350	5	RX CL. Plate	9	390.00	②
RH173CRF	19.0	13.0	5.1	200	OH/UG	#6-350	5	RX CL. Plate	9	394.00	②③④
RH173CRJ	19.0	13.0	5.1	200	OH/UG	#6-350	5	RX CL. Plate	9	394.00	②
RH173CRR	19.0	13.0	5.1	200	OH/UG	3/8-24 Stud	5	RX CL. Plate	9	394.00	②④
RH173CRJNU	28.0	13.0	5.1	200	OH/UG	#6-350	5	RX Opening	9	382.00	①
RH178CRJNU	22.0	16.0	5.0	200	OH/UG	#6-350	5	RX CL. Plate	10	467.00	①④

200 Continuous Amp Ringless Type Meter Mounting Equipment Lever Bypass, 3 Phase, 4 Wire, 600V Commercial/Industrial

Catalog Number	Dimensions (inches)			Cont. Amps	Service	Wire Range	No. of Jaws	Hub Opening	KO Fig.	List Price \$	Notes
	H	W	D								
7 TERMINAL											
RH173GR	19.0	13.0	5.2	200	OH/UG	#6-350	7	RX CL. Plate	9	495.00	②④
RH173GRF	19.0	13.0	5.2	200	OH/UG	#6-350	7	RX CL. Plate	9	506.00	②③④
RH173GRJ	19.0	13.0	5.1	200	OH/UG	#6-350	7	RX CL. Plate	9	506.00	②④
RL178GRJ	20.0	16.0	5.1	200	UG-SW	#6-350	7	RX CL. Plate	33	593.00	②④
RH173GRJNU	19.0	13.0	5.2	200	OH/UG	#6-350	7	RX Opening	9	453.00	①④
RH178GRJNU	22.0	16.0	5.0	200	OH/UG	#6-350	7	RX CL. Plate	10	537.00	①④

Contact utility or sales office for approval by your local utility prior to installation.

- ①7/16" Barrel lock knockout
- ②7/8" Barrel lock knockout
- ③Stainless steel latch and hasp
- ④Ground lug included
- ⑤No bypass installed or available