

- NOTES:
1. ALL DIMENSIONS ARE IN INCHES AND [MILLIMETERS].
  2. COMPLETE ASSEMBLY CONSISTS OF ONE CHANNEL WITH PIPE SLEEVE. ALL FASTENERS ARE SUPPLIED SEPARATELY.
  3. INSTALL IN ACCORDANCE WITH NEMA STANDARD VE-2 "CABLE TRAY INSTALLATION GUIDELINES".
  4. THIS CHANNEL IS TYPICALLY USED FOR THE ASSEMBLY OF A CENTER-HUNG TYPE CABLE TRAY SUPPORT.
  5. USE LHT SERIES SUPPORT HARDWARE KIT, CENTER CHANNEL, SUPPLIED SEPARATELY.
  6. TO ENSURE THAT CENTER CHANNEL REMAINS LEVEL, IT IS CRITICAL THAT THE WEIGHT OF CABLES BE DISTRIBUTED EVENLY INSIDE THE CABLE TRAY.


CATALOG NUMBER	W CHANNEL WIDTH (in [mm])	NOMINAL CABLE TRAY WIDTH (in [mm])
LSC12	18 [457.2]	12 [304.8]
LSC18	24 [609.6]	18 [457.2]
LSC24	30 [762.0]	24 [609.6]

LIST OF PARTS		
DESCRIPTION	MATERIAL	FINISH
CHANNEL	STEEL	HOT-DIP GALVANIZED

1	RELEASED PER DCN211102014008	AD	11/2/21
REV	DESCRIPTION	APP	DATE

THE DESIGN AND DIMENSIONS OF THE PRODUCT SHOWN ON THIS DRAWING ARE SUBJECT TO CHANGE WITHOUT NOTICE. DIMENSIONS ARE IN INCHES [mm].

TITLE  
CENTER SUPPORT CHANNEL,  
LADDER TRAY



TOLERANCES UNLESS OTHERWISE SPECIFIED .XX = ± .01 .XXX = ± .005 ANGLE TOL. ±2°	DR. BY AD	SCALE 1 / 2
	CHK. BY SBW	DATE 10/13/21